




Top View



Side View



Approved for Production

Project: _____

Date: _____

Quantity: _____

By: _____



Five generations. One goal.
BargerAndSons.com
 Quality precast concrete.

C.R. Barger & Sons, Inc.
 P.O. Box 370 - Kingston TN 37763
 Phone 865.270.8080 - BargerAndSons.com

Specifications

- Concrete:** 5,000 psi minimum strength (28 day)
- Reinforcing:** Primary reinforcement will be a #3 rebar (Grade 60) rebar.
- Pipe Penetrations:** All pipe penetrations are placed according to job requirements.
- Pipe Stands:** Adjustable height pipe stands will be provided to support assembly.
- Sealant:** Sealant used will meet or exceed ASTM C990.
- Steps:** Aligned under hatch unless specified.
- General:** Meter vaults are not water tight structures.

**2" Meter with Bypass - 33.5" Tall
 Consolidated Utility District**

Date: 2.212011

Drawn By: Eric Barger

Approx. Vault Weight: 3,050 lbs.