

Approved for Production

Quantity:

Project:	Date:





C.R. Barger & Sons, Inc. P.O. Box 370 - Kingston TN 37763 Phone 865.270.8080 - BargerAndSons.com

Specifications

Concrete: 5,000 psi minimum strength (28 day)

Reinforcing: Primary reinforcement will be a #3 rebar (Grade 60) rebar.

By:

Pipe Penetrations: All pipe penetrations are placed according to job requirements. **Pipe Stands:** Adjustable height pipe stands will be provided to support assembly.

Sealant: Sealant used will meet or exceed ASTM C990.

Steps: Aligned under hatch unless specified.

General: Meter vaults are not water tight structures.

8' x 6' Fireline Meter Assembly - 4", 6", 8" Nashville Metro Water Services Detail

ate: 4.162014 | Drawn By: Eric

Drawn By: Eric Barger

Approx. Vault Weight: 22,000 lbs.