



### Top View




1. Meter Yoke  
 $\frac{3}{4}$ " Ford VBHH72-7W-11-33-NL  
 $\frac{3}{4}$ " Mueller 234B2404-R2-N
2. Corporation Stop  
 $\frac{3}{4}$ " Ford F1600-3-NL  
 $\frac{3}{4}$ " Mueller H-10045N
3.  $\frac{3}{4}$ " x 4" and  $\frac{3}{4}$ " x 18" brass nipples  
 poly c wrap nipple through wall
4. 29" x 59" opening single leaf aluminum door, pedestrian rated (300 lb/ft<sup>2</sup>)
5. 4" or 6" D.I.P. Class 56 / PR 350
6. 2" drain hole
7. Multi-purpose adapter  
 $\frac{3}{4}$ " Ford CSSUN1-33-NL  
 $\frac{3}{4}$ " Mueller  $\frac{5}{8}$ " x  $\frac{3}{4}$ " H-14222


### Side View




### Component Detail



### End View



### Pipe detail for taps



## Approved for Production

Project: \_\_\_\_\_ Date: \_\_\_\_\_

Quantity: \_\_\_\_\_ By: \_\_\_\_\_

# BARGER PRECAST

C.R. Barger & Sons, Inc.  
 P.O. Box 370 - Kingston TN 37763  
 Phone 888.882.5860 - BargerAndSons.com

### Specifications

**Concrete:** 5,000 psi minimum strength (28 day)  
**Pipe Penetrations:** All pipe penetrations are placed according to job requirements.

## 8-Gang $\frac{3}{4}$ " Meter Vault West Knox Utility District

Date: 12.012023 Drawn By: Eric Barger Approx. Empty Vault Weight: 3,100 lbs.